


TRENCH CROSS-SECTION
FOR DEPTHS UP TO 16' - 0"

NOTE:

1. ENGINEER OF RECORD SHALL SUBMIT LIVE AND EARTH LOADING CALCULATIONS FOR DEFLECTION AND PROJECT SPECIFIC EMBEDMENT DESIGN FOR DEPTHS GREATER THAN 16 FEET.
2. WHEN WATER TABLE CRADLE IS REQUIRED TO PREVENT SOIL MIGRATION AND/OR STABILIZE PIPE FOUNDATION SEE STANDARD DETAIL 367.
3. REFER TO STANDARD DETAIL 315 FOR STANDARD TRENCH WIDTH.
4. FOR PAVED AREAS, SEE STANDARD DETAIL 713.

BEDDING DETAIL POLYVINYL CHLORIDE FLEXIBLE SANITARY SEWER PIPE	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: S.B.W. CHECKED BY: DATE: APRIL 2019	APPROVED 
NOT TO SCALE	STANDARD NO. 351

PATH NAME: /E1/PARTS/STD/DCN-STD/351-BEDDINGPVC.DGN RMO 04/04/2019