



CITY OF
Tulsa
A New Kind of *Energy*™

FAX TRANSMITTAL

Date: December 15, 2020

To: Plan Holders

Company: Contractors

Number of Pages: 3 (Including Cover)

From: Anika Ture - Contract Administration
Telephone No. 918-596-9637
Fax No. 918-699-3470
Email – ature@cityoftulsa.org

**RE: PROJECT NO. SP 18-02 ROOF REPLACEMENT – AB JEWELL
WATER TREATMENT PLANT**

ADDENDUM NO. 2

Please fax or email a signed cover sheet 918-699-3470 to or jiten@cityoftulsa.org as acknowledgement of receipt.

Thank you,

Signature

Company

Date



ENGINEERING SERVICES DEPARTMENT

December 14, 2020

**ADDENDUM NO. 2
TO
PROJECT NO. SP 18-02 ROOF REPLACEMENT – AB
JEWELL WATER TREATMENT PLANT**

This Addendum No. 2 consisting of (1) item, submitted by Cyntergy, is hereby made a part of the Contract Documents to the same extent as though it were originally included therein, and shall supersede anything contained in the Plans and Specifications with which it might conflict. **This entire Addendum shall be attached to the Index Sheet of the Contract Documents, recorded on P-4 of the proposal, and submitted with bid. Failure to do so shall result in the bid being deemed non-responsive.**

This Addendum No. 2 consists of the following:

1. The attached documents list the detail items that have been modified in Addendum No. 2. These documents shall be inclusive and apply to this project.

All other provisions of the Plans and Specifications shall remain in full force and effect.

CITY OF TULSA

For
Paul D. Zachary, P.E.
City Engineer

HAS MAH AT
HAS/MAH/AT/ji



12/11/2020

Addendum No. 2

Date: December 11, 2020

Project: ROOF REPLACEMENTS A.B. JEWELL WATER TREATMENT PLANT
Project No. – SP 18-02

To: Max Wells

This Addendum No. 2, consists of revisions to the drawings that are a part of the Contract Documents to the same extent as though it were originally included therein, and shall supersede anything contained in the Plans and Specifications with which it might conflict.

This Addendum No. 2 consists of the following:

Drawings

1. P-1 PAY ITEMS - Add to Pay Item Note for Pay Item #20 RETROFIT ROOF DRAIN the following: Contractor shall inspect and clear as required all storm drainage piping including underground storm drain lines from the entry point of the drains affected or added with this work to where the drain lines either daylight or tie into the main storm drainage system to ensure they flow freely.

End of Addendum No. 2



CYNERGY ENGINEERING, PLLC
CA # 3537
EXPIRES 6/30/2022

Larry L. Vorba, PE #11654
Project Manager
Cynergy,