


NOTE:
ALL DRIVES IN THE FIREPROOF AREA SHALL BE RAMP TYPE WITH A MINIMUM CURB OPENING OF 24' AND MAXIMUM OF 36'.

NOTE:
CONSTRUCTION SHALL BE IN ACCORDANCE WITH STANDARDS 701 THROUGH 704 EXCEPT THAT COMMERCIAL DRIVES INCLUDING SIDEWALKS IN DRIVE AREAS SHALL BE A MINIMUM OF 6" THICK.

NOTE:
SIDEWALKS AND RAMPS SHALL MEET THE ADA ACCESSIBITIY TECHNICAL REQUIREMENTS AS SHOWN AT WWW.ACCESS-BOARD.GOV/PROWAG/

COMMERCIAL DRIVEWAY	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O. CHECKED BY: DATE: MARCH 2021	APPROVED 
NOT TO SCALE	STANDARD NO 707