



NOTE:

- SERV. CLAMP REQUIRED FOR ALL SIZES PVC, AND FOR 4" AND SMALLER IRON. FOR 6" AND LARGER IRON, TAP DIRECTLY.
- TAP AT ANGLE NECESSARY TO PROVIDE 30' OF COVER OVER THE SERVICE LINE.
- COPPER SERVICE LINES SHALL BE TYPE K SOFT ANNEALED.

| | |
|---|------------------|
| STANDARD METER SETTINGS FOR 5/8" X 3/4" AND 3/4" WATER SERVICE | |
| CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT | |
| DRAWN BY: S.B.W. CHECKED BY: DATE: SEPTEMBER 2021 | APPROVED |
| NOT TO SCALE | STANDARD NO. 501 |