



- NOTE:
- SERV. CLAMP REQUIRED FOR ALL SIZES PVC, AND FOR 4" AND SMALLER IRON. FOR 6" AND LARGER IRON, TAP DIRECTLY.
  - TAP AT ANGLE NECESSARY TO PROVIDE 30" OF COVER OVER THE SERVICE LINE.
  - LOCATE PEX LINE AT LEAST 50 FEET HORIZONTALLY FROM ANY GASOLINE STORAGE TANK AND LINES.
  - PEX SHALL BE 1" MINIMUM.

UPONOR AQUA PEX BLUE 5306 OR VIEGA PUREFLOW PEX BLUE 5306 TO BE USED ON NON-ARTERIAL STREETS ONLY

STANDARD METER SETTINGS FOR 5/8" X 3/4" AND 3/4" WATER SERVICE

CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT

DRAWN BY: R.M.O.  
CHECKED BY:  
DATE: AUGUST 2021

APPROVED  
*[Signature]*

NOT TO SCALE

STANDARD NO. 501A