



- NOTE:**
- SERV. CLAMP REQUIRED FOR ALL SIZES PVC, AND FOR 6" AND SMALLER IRON. FOR 8" AND LARGER IRON, TAP DIRECTLY.
 - TAP AT ANGLE NECESSARY TO PROVIDE 30° OF COVER OVER THE SERVICE LINE.
 - COPPER SERVICE LINES SHALL BE TYPE K SOFT ANNEALED.

STANDARD METER SETTINGS FOR 1" WATER SERVICE	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O. CHECKED BY: DATE: AUGUST 2021	APPROVED
NOT TO SCALE	STANDARD NO. 502