



MINIMUM TRENCH WIDTH FOR FLEXIBLE PIPES	
PIPE I.D.	MIN. TR. WIDTH
8" - 12"	3' - 0"
14" - 18"	4' - 6"
20" - 24"	6' - 0"
26" - 30"	7' - 6"
32" - 36"	9' - 0"

NOTE:

1. SLIDING TRENCH SUPPORTS SHALL NOT BE PLACED BELOW THE TOP OF THE PIPE.
2. WATER TABLE CRADLE SHALL BE INSTALLED FOR THE FULL WIDTH OF THE TRENCH EXCAVATION.
3. FOR RIGID PIPES USE THE STD. TRENCH WIDTH. SEE TABLE FOR FLEXIBLE PIPES.

NOTE:
FLEXIBLE PIPES ARE PE, ASTM F894 AND PVC, ASTM D3034, ASTM F679 AND ASTM F794 FOR ALL OTHER PIPES USE THE STANDARD TRENCH WIDTH.

STANDARD DETAIL WATER TABLE CRADLE	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O. CHECKED BY: <i>HAS</i> DATE: MARCH 2022	APPROVED <i>[Signature]</i>
NOT TO SCALE	STANDARD NO. 367