

FOR COPPER SERV. LINE SPLICING, USE FLARE END 3-PART UNION
 MUELLER H15403 OR H15400,
 FORD C22, HAYS 5615,
 JONES J1528 OR J2609,
 McDONALD 4758.
 FLARED OR COMPRESSION

CORPORATION STOP
 MUELLER H15000,
 FORD F600, HAYS 5200,
 JONES J1500 OR J3401,
 McDONALD 4701.
 FLARED ONLY


SINGLE VALVE TYPE METER SETTER WITH LOCKWINGS AND 18" EXTENSION;
 FORD 70 (V OR VB) SERIES,
 MUELLER H24104 OR B24104,
 McDONALD 60 SERIES.

NOTE:
 LEAD SOLDER IS NOT PERMITTED ON METER SETTER ASSEMBLY.


UNDISTURBED EARTH OR 4" GRAVEL

OUTSIDE I.P. THREAD CONNECTION
 DIELECTRIC UNION, ONLY FOR METAL CUST. S.L.

SERVICE CLAMP
 TAP ON D.I.P. - FORD STYLE F202, MUELLER H10500 SERIES
 TAP ON P.V.C. - FORD STYLE S90, MUELLER H13400 SERIES, POWERSEAL 3405
 TAP ON HDPE - POLY-CAM 415 OR 575



45 ³³/₆₄ TAP



SIDE TAP

NOTE:

- SERV. CLAMP REQUIRED FOR ALL SIZES PVC, AND FOR 6" AND SMALLER IRON. FOR 8" AND LARGER IRON, TAP DIRECTLY.
- TAP AT ANGLE NECESSARY TO PROVIDE 30° OF COVER OVER THE SERVICE LINE.
- COPPER SERVICE LINES SHALL BE TYPE K SOFT ANNEALED.

| | |
|--|--------------------------------|
| STANDARD METER SETTINGS FOR 1" WATER SERVICE | |
| CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT | |
| DRAWN BY: R.M.O. CHECKED BY: <i>HAS</i> DATE: MARCH 2022 | APPROVED <i>[Signature]</i> |
| NOT TO SCALE | STANDARD NO. 502 |