



①

OVERHEAD ONLY

②

OPEN CUT ** OR BORE

③

BORE ONLY **

OPTIONS	
<input type="checkbox"/>	① OVERHEAD ONLY
<input type="checkbox"/>	② OPEN CUT OR BORE
<input type="checkbox"/>	③ BORE ONLY

- * CROSSING ABOVE THE RAW WATER FLOWLINES (RWF) IS FOR POTABLE WATERLINE ONLY
- ** PUSHING/RECEIVING PITS MUST BE A MINIMUM OF 10' FROM PROPERTY LINE
- *** CASING AS REQUIRED BY CITY OF TULSA. VENT PIPE AS REQUIRED
- **** OVERHEAD POLE OR GUYWIRE MUST BE A MINIMUM OF 10' FROM PROPERTY LINE

N.T.S.

TYPICAL UTILITY CROSSING OF RAW WATER FLOWLINES (RWF)	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O. CHECKED BY: <i>HAS</i> DATE: MARCH 2022	APPROVED
NOT TO SCALE	STANDARD NO. 509