



NOTE:
 ALL DRIVES IN THE FIREPROOF AREA SHALL BE RAMP TYPE WITH A MINIMUM CURB OPENING OF 24' AND MAXIMUM OF 36'.

NOTE:
 CONSTRUCTION SHALL BE IN ACCORDANCE WITH STANDARDS 701 THROUGH 704 EXCEPT THAT COMMERCIAL DRIVES INCLUDING SIDEWALKS IN DRIVE AREAS SHALL BE A MINIMUM OF 6" THICK.

NOTE:
 SIDEWALKS AND RAMPS SHALL MEET THE ADA ACCESSIBITIY TECHNICAL REQUIREMENTS AS SHOWN AT WWW.ACCESS-BOARD.GOV/PROWAG/

COMMERCIAL DRIVEWAY	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: R.M.O. CHECKED BY: <i>HAS</i> DATE: MARCH 2022	APPROVED: <i>[Signature]</i>
NOT TO SCALE	STANDARD NO. 707