



PUBLIC WORKS
Engineering

DATE:
November 13, 2024

TO:
Plan Holders

Contractors

FROM:
Jenna Richardson

918-596-9637

jennarichardson@cityoftulsa.org

EMAIL TRANSMITTAL

ADDENDUM NO. 1

**PROJECT NO. ES 2022-05 NORTHSIDE AERATION JOCKEY
BLOWER ADDITION**

Number of pages: **3**

Please email a signed cover sheet to kteel@cityoftulsa.org
as acknowledgement of receipt.

Thank you,

Signature

Company

Date



WATER AND SEWER
Engineering Design

DATE:

November 15, 2024

**ADDENDUM NO. 1
TO
PROJECT NO. ES 2022-05 NORTHSIDE AERATION JOCKEY BLOWER
ADDITION**

This Addendum No. 1 consisting of one (1) clarification, submitted by Tetra Tech is hereby made a part of the Contract Documents to the same extent as though it were originally included therein and shall supersede anything contained in the Plans and Specifications with which it might conflict. **This entire Addendum shall be attached to the Index Sheet of the Contract Documents and recorded on the last page of the proposal and submitted with bid. Failure to do so shall result in the bid being deemed non-responsive.**

This Addendum No. 1 consists of the following:

1. The attached documents list the detail items that have been modified in Addendum No. 1. These documents shall be inclusive and apply to this project.

All other provisions of the Plans and Specifications shall remain in full force and effect.

CITY OF TULSA

Eric Lee
Director

For

HAS/TGP/ATL/JR/kt

1836 x 1836

TUL * USA

November 12, 2024

**ADDENDUM NO. 1
TO
PROJECT NO. TMUA ES 2022-05
NORTHSIDE AERATION JOCKEY BLOWER**

This Addendum No. 1, consisting of one (1) clarification, is hereby made a part of the Contract Documents to the same extent as though it were originally included therein, and shall supersede anything contained in the Plans and Specifications with which it might conflict. **This Addendum shall be attached to the Index Sheet of the Contract Documents and submitted with the bid. Failure to do so shall result in the bid being deemed non-responsive.**

CLARIFICATIONS

Bidder Questions and Answers in **bold**:

1. QUESTION: Should schedule 40 be used for the air piping in the blower room?

ANSWER: The air piping in the blower room shall be Schedule 10, per specification 40 27 00.08A.

All other provisions of the Plans and Specifications shall remain in full force and effect.

BY *Alexandria Belle Kindrick*
Alexandria Belle Kindrick, P.E.

DATE/SEAL: 11/12/2024

