



--- LIMITS OF STANDARD BEDDING MATERIAL
 QUANTITIES FOR BEDDING MATERIAL DO NOT
 INCLUDE THE SPACE WITHIN AND BOUNDED BY
 THE OUTER SURFACE OF THE PIPE CONDUIT.

NOTE:
 STANDARD BEDDING MATERIAL MUST BE ODOT TYPE "A" AGGREGATE
 BASE. UNDER PAVING, TYPE "A" AGGREGATE BASE MUST BE TO THE
 TOP OF THE TRENCH. TYPE "A" AGGREGATE BASE TO BE COMPACTED
 TO 95% STANDARD PROCTOR DENSITY.

PIPE SIZE, IN.	TRENCH WIDTH, FT.
ID < 24"	OD + 2'
24" > ID < 36"	OD + 2.5'
36" > ID < 60"	OD + 3.5'
ID \leq 60"	OD + 2' EACH SIDE OF PIPE

STANDARD PIPE BEDDING DETAIL FOR STORM SEWER	
CITY OF TULSA, OKLAHOMA ENGINEERING SERVICES DEPARTMENT	
DRAWN BY: S.R.W.	APPROVED: 
CHECKED BY:	
DATE: OCTOBER 2013	
NOT TO SCALE	STANDARD NO. 751