

* The City of Tulsa is required to perform reduced lead and copper monitoring. Fifty lead and copper tap water samples are collected annually between June 1st and September 30th.

* Regulatory Action Levels (ALs) that require action from the Public Water Supply are based on 90th percentile values. The AL for lead is 15 ug/L and 1.3 mg/L for copper.

* The 90th percentile concentration for tap water samples collected during the 2025 monitoring period is 1.20 ug/L for lead and 0.304 mg/L for copper.

* All results indicated BDL were below the lowest concentration the laboratory can detect.

Rank	LC-CODE	ADDRESS	Sample Date	Lead (µg/L)	
50	LC038	5510 E. 75th St.	7/15/2025	3.98	
49	LC083	8419 S. 78th E. Ave	7/23/2025	3.53	
48	LC090	1034 E 32nd PL	7/22/2025	3.42	
47	LC206	4501 E 107th ST	8/5/2025	2.41	
46	LC152	2514 W 68th PL	7/24/2025	1.22	
45	LC272	8525 E 77th PL	7/30/2025	1.20	90th Percentile
44	LC129	1404 S 110th East Pl	7/16/2025	1.04	
43	LC249	7405 S TRENTON AVE	8/5/2025	1.01	
42	LC284	9014 S 77th East Pl	7/29/2025	0.939	
41	LC201	4134 S NORFOLK AVE	7/29/2025	0.918	
40	LC241	6824 S 30th West Ave	8/5/2025	0.874	
39	LC101	12118 E 29th PL	7/15/2025	0.868	
38	LC172	2908 S 125th East Ave	8/6/2025	0.816	
37	LC103	12209 E 30th ST	7/16/2025	0.798	
36	LC264	7771 S CANTON AVE	7/30/2025	0.740	
35	LC094	10702 S TOLEDO AVE	7/30/2025	0.715	
34	LC248	7325 S ELWOOD AVE	7/29/2025	0.697	
33	LC229	6211 E 76th ST	8/6/2025	0.658	
32	LC199	4029 S 118th East Ave	8/5/2025	0.646	
31	LC133	14262 E 37th PL	7/30/2025	0.622	
30	LC158	2716 W 67th ST	7/30/2025	0.595	
29	LC281	8921 E 86th ST	8/7/2025	0.573	
28	LC028	9725 S. 95th E. Ave	7/15/2025	BDL (0.500)	
27	LC121	13424 E 45th ST	7/15/2025	BDL (0.500)	
26	LC064	7529 S. Trenton	7/15/2025	BDL (0.500)	
25	LC037	1928 W. 61st Pl.	7/16/2025	BDL (0.500)	
24	LC010	1543 S. Gillette	7/17/2025	BDL (0.500)	
23	LC164	2803 W 64th ST	7/17/2025	BDL (0.500)	
22	LC088	10123 S GRANITE AVE	7/17/2025	BDL (0.500)	
21	LC157	2702 S 137th East Ave	7/22/2025	BDL (0.500)	
20	LC115	13104 E 45th ST	7/22/2025	BDL (0.500)	
19	LC109	1243 E 24th ST	7/22/2025	BDL (0.500)	
18	LC106	12313 E 27th PL	7/22/2025	BDL (0.500)	
17	LC166	2806 W 62nd ST	7/22/2025	BDL (0.500)	
16	LC193	3812 S 135th East Pl	7/23/2025	BDL (0.500)	
15	LC108	12418 E 35th ST	7/24/2025	BDL (0.500)	
14	LC222	5944 S BIRMINGHAM AV	7/29/2025	BDL (0.500)	
13	LC236	6710 S 29th West Ave	7/29/2025	BDL (0.500)	
12	LC138	1521 S 139th East Ave	7/29/2025	BDL (0.500)	
11	LC266	7855 S 69th East Ave	8/5/2025	BDL (0.500)	
10	LC233	6406 E 75th ST	8/5/2025	BDL (0.500)	
9	LC262	7742 S ERIE AVE	8/5/2025	BDL (0.500)	
8	LC184	3156 S OWASSO AVE	8/5/2025	BDL (0.500)	
7	LC111	12441 E 35th ST	8/6/2025	BDL (0.500)	
6	LC156	2634 W 68th ST	8/6/2025	BDL (0.500)	
5	LC091	10603 E 100th ST	8/6/2025	BDL (0.500)	
4	LC086	10207 E. 98th St.	8/7/2025	BDL (0.500)	
3	LC130	1407 S 111th East Ave	8/7/2025	BDL (0.500)	
2	LC151	2450 E 28th ST	8/8/2025	BDL (0.500)	
1	LC286	9119 S 89th East Ave	8/12/2025	BDL (0.500)	

* The City of Tulsa is required to perform reduced lead and copper monitoring. Fifty lead and copper tap water samples are collected annually between June 1st and September 30th.

* Regulatory Action Levels (ALs) that require action from the Public Water Supply are based on 90th percentile values. The AL for lead is 15 ug/L and 1.3 mg/L for copper.

* The 90th percentile concentration for tap water samples collected during the 2025 monitoring period is 1.20 ug/L for lead and 0.304 mg/L for copper.

* All results indicated BDL were below the lowest concentration the laboratory can detect.

Rank	LC-CODE	ADDRESS	Sample Date	Copper (mg/L)	
50	LC109	1243 E 24th ST	7/22/2025	0.377	
49	LC206	4501 E 107th ST	8/5/2025	0.365	
48	LC133	14262 E 37th PL	7/30/2025	0.339	
47	LC129	1404 S 110th East Pl	7/16/2025	0.328	
46	LC233	6406 E 75th ST	8/5/2025	0.321	
45	LC272	8525 E 77th PL	7/30/2025	0.304	90th Percentile
44	LC262	7742 S ERIE AVE	8/5/2025	0.300	
43	LC111	12441 E 35th ST	8/6/2025	0.300	
42	LC166	2806 W 62nd ST	7/22/2025	0.299	
41	LC103	12209 E 30th ST	7/16/2025	0.290	
40	LC184	3156 S OWASSO AVE	8/5/2025	0.285	
39	LC091	10603 E 100th ST	8/6/2025	0.275	
38	LC088	10123 S GRANITE AVE	7/17/2025	0.265	
37	LC094	10702 S TOLEDO AVE	7/30/2025	0.255	
36	LC157	2702 S 137th East Ave	7/22/2025	0.248	
35	LC115	13104 E 45th ST	7/22/2025	0.246	
34	LC241	6824 S 30th West Ave	8/5/2025	0.230	
33	LC201	4134 S NORFOLK AVE	7/29/2025	0.227	
32	LC284	9014 S 77th East Pl	7/29/2025	0.220	
31	LC086	10207 E. 98th St.	8/7/2025	0.219	
30	LC090	1034 E 32nd PL	7/22/2025	0.210	
29	LC101	12118 E 29th PL	7/15/2025	0.194	
28	LC264	7771 S CANTON AVE	7/30/2025	0.194	
27	LC106	12313 E 27th PL	7/22/2025	0.180	
26	LC121	13424 E 45th ST	7/15/2025	0.178	
25	LC229	6211 E 76th ST	8/6/2025	0.177	
24	LC172	2908 S 125th East Ave	8/6/2025	0.174	
23	LC156	2634 W 68th ST	8/6/2025	0.173	
22	LC199	4029 S 118th East Ave	8/5/2025	0.170	
21	LC152	2514 W 68th PL	7/24/2025	0.169	
20	LC038	5510 E. 75th St.	7/15/2025	0.167	
19	LC064	7529 S. Trenton	7/15/2025	0.163	
18	LC236	6710 S 29th West Ave	7/29/2025	0.152	
17	LC138	1521 S 139th East Ave	7/29/2025	0.148	
16	LC281	8921 E 86th ST	8/7/2025	0.148	
15	LC083	8419 S. 78th E. Ave	7/23/2025	0.144	
14	LC222	5944 S BIRMINGHAM AVE	7/29/2025	0.115	
13	LC028	9725 S. 95th E. Ave	7/15/2025	0.111	
12	LC151	2450 E 28th ST	8/8/2025	0.0963	
11	LC266	7855 S 69th East Ave	8/5/2025	0.0939	
10	LC249	7405 S TRENTON AVE	8/5/2025	0.0838	
9	LC037	1928 W. 61st Pl.	7/16/2025	0.0748	
8	LC286	9119 S 89th East Ave	8/12/2025	0.0692	
7	LC108	12418 E 35th ST	7/24/2025	0.0539	
6	LC248	7325 S ELWOOD AVE	7/29/2025	0.0469	
5	LC130	1407 S 111th East Ave	8/7/2025	0.0363	
4	LC193	3812 S 135th East Pl	7/23/2025	0.035	
3	LC158	2716 W 67th ST	7/30/2025	0.0342	
2	LC010	1543 S. Gillette	7/17/2025	0.0332	
1	LC164	2803 W 64th ST	7/17/2025	0.0155	