



PUBLIC WORKS
Engineering

DATE: September 22, 2025

TO: PAUL ZACHARY,
PUBLIC WORKS DEPUTY
DIRECTOR

FROM: ^{HAS} H. SOMDECERFF,
PUBLIC WORKS DESIGN
MANAGER

The Specification Review Committee recommends and asks the Public Works Deputy Director to approve the following:

1. Approve Modification to Division 306 - Pipe, Concrete.
Summary of change: To update AWWA, ANSI, ASTM, and ASME references.

Please call Marqua Jimmerson at (918) 596-7355 If you have any questions.

Thank you,

APPROVED:



Paul Zachary, Deputy Director



Date

Cc: Public Works Engineering Services Specification Review Committee

PART 306 – PIPE, CONCRETE

- 306.1 The work under this item shall include furnishing, delivery, placing and jointing of reinforced concrete pipe (RCP) and prestressed concrete cylinder pipe (PCCP) in the trench in specific conformity with the lines and levels given.
- 306.2 For water, AWWA C301/C304 PCCP shall be used, and the current edition of AWWA Manual M9 shall govern the installation as applicable. For storm sewer lines, ASTM C76 RCP shall be used, and the current edition of ASTM C1479/C1479M, Standard Practice for Installation of Precast Concrete Sewer, Storm Drain, and Culvert Pipe Using Standard Installation shall govern the installation as applicable. The Drawings show the plan and grade for the pipeline. The Contractor shall submit detailed drawings to the Engineer for approval, showing the proposed method of laying the pipe to these grades. All pipelines to be crossed shall be located by the Contractor before these drawings are prepared. The ends of the pipes to be jointed shall be cleaned immediately prior to jointing and the rubber gasket thoroughly lubricated with vegetable soap before it is placed in position on the spigot end. Extreme care shall be taken when moving the spigot end of the pipe into the bell end of previously laid pipe. If the gasket is damaged or moved out of place, the new pipe shall be removed, and a new gasket applied before rejoining. Any soap remaining on the exposed concrete surfaces inside or outside the pipe shall be completely removed. Fittings or specials included as pipe shall be blocked in accordance with the Standard Details.
- 306.3 For storm sewers, the methods of laying pipe, foundation, and grade specified under Part 305-Pipe, Vitrified Clay, shall apply. All pipe shall be installed with the mark "C-76" visible on the top of the pipe. The ends of the pipes to be jointed shall be cleaned immediately prior to joining and the rubber gasket. Extreme care shall be taken when moving the spigot end of the pipe into the bell end of previously laid pipe. If the gasket is damaged or moved out of place, the new pipe shall be removed, and a new gasket applied before rejoining.
- 306.4 For all lines, after the pipe has been jointed, a band at least 5-1/2 inches wide shall be placed around the outside of the pipe at the joint. This band shall serve as a form for placing 1:1 cement mortar grout in the external recess formed by the face of the groove and the shoulder of the tongue. If a reinforced paper joint band is used, it shall be drawn up tight around the pipe and the backfill tamped against it up to the spring line before pouring the grout. If a cloth band is used, it shall be wired around the outside of the pipe, and the grout poured before backfilling. On all pipes, the joint space remaining on the inside of the pipe shall be filled with a stiff mixture of 1:1 cement mortar which shall be troweled in place to produce a continuous, smooth, flush surface across the joint.
- 306.5 Payment: Payment for this item shall be made at the unit price bid per linear foot of pipe of the type specified in the Proposal and placed as shown on the Drawings. Total footage shall be the actual horizontal measurement along the centerline of the pipe. No additional payment shall be made for vertical pipe or fittings used with drop manholes, for fittings or specials included as pipe, or for concrete blocking or interior coatings.