



PUBLIC WORKS
Engineering

DATE:
April 6, 2026

TO:
Plan Holders
Contractors

FROM:
Jenna Richardson
918-596-9637
jennarichardson@cityoftulsa.org

EMAIL TRANSMITTAL

ADDENDUM NO. 2

**PROJECT NO. WPC 26-4 FY'26 WATER POLLUTION CONTROL
SOUTHSPLOE CAPITAL EQUIPMENT REPLACEMENTS**

Number of pages: **3**

All addenda to the contract documents should be denoted on the
last page of the Proposal in the space provided.

Thank you,
Contract Administration

TULSA METROPOLITAN UTILITY AUTHORITY

175 E. 2nd Street

TULSA, OKLAHOMA 74103

April 6, 2026

**ADDENDUM 2
TO
TULSA METROPOLITAN UTILITY AUTHORITY
PROJECT NO. WPC 26-4
FY'26 WATER POLLUTION CONTROL
SOUTHSLOPE CAPITAL EQUIPMENT REPLACEMENTS**

This Addendum 2 consisting of two (2) items is, hereby, made a part of the Contract Documents to the same extent as though it were originally included, therein, and shall supersede anything contained in the Plans and Specifications with which it might conflict. Receipt of this Addendum 2 shall be denoted in Bidder's Proposal. Failure to do so will result in the bid being deemed non-responsive.

All other provisions of the Plans and Specifications shall remain in full force and effect.

CITY OF TULSA WATER AND SEWER DEPARTMENT



Cindy Cantero
Water Pollution Control Manager



WATER AND SEWER

DATE:

April 6, 2026

Ms. Cindy Cantero
Water Pollution Control Section Manager
175 East 2nd Street, 13th Floor
Tulsa, Oklahoma 74103

RE: TMUA PROJECT NO. WPC 26-4, FY'26 SOUTHSLOPE CAPITAL EQUIPMENT REPLACEMENTS
SUBJECT: ADDENDUM 2 - 4/6/2026

Dear Ms. Cantero:

This Addendum 2 consisting of two (2) items is, hereby, made a part of the Contract Documents to the same extent as though it were originally included, therein, and shall supersede anything contained in the Plans and Specifications with which it might conflict. Receipt of this Addendum 2 shall be denoted in Bidder's Proposal. Failure to do so will result in the bid being deemed non-responsive.

1. Refer to Specification No. 214.04 - Sludge Transfer Pump STP01
 - a. 214.04.07 - For The Seepex Option, for the PARAMETER "Rotor Assembly," change the VALUE to "Standard."
 - b. 214.04.07 - For The Seepex Option, for the PARAMETER "Stator Assembly," change the VALUE to "Standard."
 - c. 214.04.18 - Change the first sentence in this paragraph to read as follows:
 "Spare Parts: With The Seepex Option provide the following spare parts: (1) stator, (1) rotor, (2) sets of universal joint assemblies and (2) mechanical seals."

2. Refer to Specification No. 214.05 - Sludge Transfer Pump STP02
 - a. 214.05.07 - For The Seepex Option, for the PARAMETER "Rotor Assembly," change the VALUE to "Standard."
 - b. 214.05.07 - For The Seepex Option, for the PARAMETER "Stator Assembly," change the VALUE to "Standard."
 - c. 214.05.18 - Change the first sentence in this paragraph to read as follows:
 "Spare Parts: With The Seepex Option provide the following spare parts: (1) stator, (1) rotor, (2) sets of universal joint assemblies and (2) mechanical seals."

Sincerely,



April 6, 2026

Samuel H. Ray, P.E., S.E.

1836 x 1898

TUL x USA